

Toll Free: 1-888-865-6888

Tel: 510-226-8368 Fax: 510-226-8968

Email: sales@RackmountMart.com

# **User Manual**

## **1U Rackmount Monitoring Fan Unit**





RA4015-3-M



**RA4015-6-M** 



RA 4015-9-M

#### **Legal Information**

First English printing, October 2002

Information in this document has been carefully checked for accuracy; however, no guarantee is given to the correctness of the contents. The information in this document is subject to change without notice. We are not liable for any injury or loss that results from the use of this equipment.

### **Safety Instructions**

# Please read all of these instructions carefully before you use the device. Save this manual for future reference.

- Unplug equipment before cleaning. Don't use liquid or spray detergent; use a moist cloth.
- Keep equipment away from excessive humidity and heat. Preferably, keep it in an air-conditioned environment with temperatures not exceeding 40° Celsius (104° Fahrenheit).
- When installing, place the equipment on a sturdy, level surface to prevent it from accidentally falling and causing dam age to other equipment or injury to persons nearby.
- When the equipment is in an open position, do not cover, block or in any way obstruct the gap between it and the power supply. Proper air convection is necessary to keep it from overheating.
- Arrange the equipment's power cord in such a way that others won't trip or fall over it.
- If you are using a power cord that didn't ship with the equipment, ensure that it is rated for the voltage and current labeled on the equipment's electrical ratings label. The voltage rating on the cord should be higher than the one listed on the equipment's ratings label.
- Observe all precautions and warnings attached to the equipment.
- If you don't intend on using the equipment for a long time, disconnect it from the power outlet to prevent being dam aged by transient over-voltage.
- Keep all liquids away from the equipment to minimize the risk of accidental spillage. Liquid spilled on to the power supply or on other hardware may cause damage, fire or electrical shock.
- Only qualified service personnel should open the chassis. Opening it yourself could damage the equipment and invalidate its warranty.
- If any part of the equipment becomes damaged or stops functioning, have it checked by qualified service personnel.

#### What the warranty does not cover

- Any product, on which the serial number has been defaced, modified or removed.
- Damage, deterioration or malfunction resulting from:
  - Accident, misuse, neglect, fire, water, lightning, or other acts of nature, unauthorized product modification, or failure to follow instructions supplied with the product.
     Repair or attempted repair by anyone not authorized by us.
  - $\hfill \square$  Any damage of the product due to shipment.
  - ☐ Removal or installation of the product.
  - ☐ Causes external to the product, such as electric power fluctuation or failure.
  - ☐ Use of supplies or parts not meeting our specifications.
  - □ Normal wear and tear.
  - ☐ Any other causes which does not relate to a product defect.
- Removal, installation, and set-up service charges.

#### Regulatory Notices Federal Communications Commission (FCC)

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation.

Any changes or modifications made to this equipment may void the user's authority to operate this equipment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications.

However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Re-position or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.

## **Unpacking**


The equipment comes with the standard parts shown on the package contents. Check and make sure they are included and in good condition. If anything is missing, or damage, contact the supplier immediately.


### **Package Content**


- 1U rackmount fan tray x 1 pc
- Temp. sensor x 1 pc
- 6 ft power cord x 1 pc
- Rear mounting bracket x 1 pair
  - \* Bracket for RA4015-6-M & RA4015-9-M only
  - \* M6 screws for fixing are not included

### Installation









## **Specifications**

Fan	RA 4015-3-M	RA 4015-6-M	RA4015-9-M
No. of Fans :	3	6	9
Individual Fan CFM:	108 CFM		
Unit CFM ( approx. ):	324 CFM 648 CFM 972 CFM		

Temperature Sensor	
Temperature Port	1 x temperature sensor port ( sensor bundled )
Measurement Range	0 to 99.9°C
Measurement Accuracy	+/- 1.5%
Temperature Alarm	Yes

Environmental	
Operating:	0 to 50°C Degree
Storage :	-5 to 60°C Degree
Relative humidity :	5~90%, non-condensing
Shock:	50G peak acceleration ( 11ms, half-sine wave )
Vibration :	58~100Hz / 0.98G ( 11ms / cycle )

Weight			
Net :	4 kgs ( 8.8 lbs )	6.8 kgs ( 15 lbs )	9 kgs ( 19.8 lbs )

Casing Color:	Black

Mounting: 10 rackmount
------------------------

Regulatory :	FCC, CE


Power			
Input :	Auto-sensing, 100V or 240V AC at 50 or 60Hz via IEC type cord		
Consumption :	20W	40W	60W


Dimensions			
Product :	480 x 298.3 x 43.5 mm	480 x 458.3 x 43.5 mm	480 x 623.3 x 43.5 mm
	18.9 x 11.7 x 1.71 inch	18.9 x 18 x 1.71 inch	18.9 x 24.5 x 1.71 inch


Regulatory	FCC & CE
Environmental	RoHS2 & REACH compliant


### **Dimensions**

RA 4015-3-M










### Front Control ON / OFF Button & Fan Status LED


### RA4015-3-M




#### RA4015-6-M



### RA4015-9-M



## **Temperature Sensor**



### **Bundled Temp. Sensor**

Part no. : EMS-101-2

- Plug & Play
- External sensor with 2M cord
- Low profile design with magnetic base for easy affixing to the rack cabinet

Optional 4M cord for Temp. Sensor

## **Temperature Sensor Specification**

FC (E REACH

	ROHS TIME TO STATE OF THE PARTY		
		Temp. Sensor	
Part no.		EMS-101-2	
Temperature	Range	0 to 80°C(32 to 176°F)	
Sensitivity	Accuracy	±1°C ( ±2°F)	
	Resolution	0.1°C (0.2°F)	
	Response Time	5 to 30 sec	
Power	Voltage	12VDC, powered by sensor port	
Requirement	Current Consumption	20mA	
	Power consumption	0.24 Watt	
	Power on indicator	Green	
Housing	Chassis & Cover	Plastic	
	Color	Dark gray	
	Installation	Magnetic base for unrestricted installation	
Connection	Cable Length	T sensor w/ 2m cable ( standard ) T sensor w/ 4m cable ( option )	
	Cable Specification	4-wired 3.5mm to RJ11	
	Cable Color	Beige	
Environmental	Operating	0 to 80°C Degree	
	Storage	-5 to 80°C Degree	
	Humidity	0~100%, non-condensing	
Dimensions	Product	30L x 25W x 18H mm	
Weight	Net	66g	
Supply includes	1	Temperature Sensor	
	2	4-wired 3.5mm to RJ11 cable ( 2m, black color )	
Compatibility		W / WS / Wi / WSi series PDU	
	RA4015-M / R / IP Series		
	EM1001 / 1002 Series		
Safety Regulatory		FCC & CE certified	
Environmental		RoHS2 & REACH compliant	

The company reserves the right to modify product specifications without prior notice and assumes no responsibility for any error which may appear in this publication.

All brand names, logo and registered trademarks are properties of their respective owners.

Copyright 2013 Synergy Global Technology Inc. All rights reserved.